

FIRE PROTECTION IMPAIRMENT NOTIFICATION



**All Impairments to Fire Protection Systems exceeding 12 hours (or overnight)
should be strictly controlled and authorized by Site Management.
ACE USA should be notified by fax 48 hours in advance or as soon as possible.**

(Completed forms should be filed for review.)

FAX TO:	ACE USA Property Engineering ATTN: M. Castellano	FAX: (212) 703-7040 Phone: (800) 447-5677
Company Name:		
Location:		
Impairment From:	Date:	Time:
Impairment To:	Date:	Time:
Equipment & Areas Effected:		
Reason for Impairment:		
Precautions Taken: (circle Y or N)	1. Fire Brigade Notified Y or N 2. Cutting & Welding work banned Y or N 3. System reinstated overnight Y or N 4. Extra fire extinguishers provided in impairment area Y or N 5. Extra security patrols in impairment area Y or N 6. Area of impairment should be minimised (i.e. part of floor or whole floor not whole or bld.) Y or N 7. If sprinkler system is impaired it should be ensured that after the area involved is drained down, the following equipment should be put back on line by the contractor: a) Diesel and/or Electric pump: Y or N b) Fire Indicator Panel: Y or N c) All valves restored to normal operating condition: Y or N	
ACE Notified:	Date:	Time:
Notified By:	Name:	Signature:
	Position:	Phone:
SYSTEM RESTORED		
System Restored:	Date:	Time:
ACE Notified By:	Name:	Signature:
	Position:	Phone: